


## Disclaimer: this layout is purely indicative. It does not replace consultant's design



## LEGEND

- 1 . Domestic water expansion vessel
- 3 . Domestic water safety valve (6 bar)
- 4 . Strainer
- 5 . Pressure reducing valve
- 7 . DHW 3-way valve
- 8 . Vent with valve

1,2

- 9 . Solar system control unit
- 10 . Solar system safety kit

- 11 . Solar system expansion vessel
- 12 . Heating system expansion vessel
- 14. Heating system safety valve

## TW\_ HP Domestic Hot Water performance

The second secon			
CODE	TW_ HP 00300 R	TW_ HP 00400 R	
DHW Heat exchanger m² (L)	4,0 (13,7)	5,0 (17,0)	
Power (kW)	36,0	45,0	
DHW Continuous draw <sup>(1)</sup> (L/h)	884	1105	
DHW <sup>(2)</sup> producible with a 10 L/min flow rate, with a totally heated buffer			
and a not running heat source			
Buffer at 55 °C (L)	82	112	
Buffer at 65 °C (L)	185	252	
Buffer at 70 °C (L)	269	367	
DHW <sup>(2)</sup> producible with a 20 L/min flow rate, with a totally heated buffer			
and a not running heat source			
Buffer at 55 °C (L)	45	61	
Buffer at 65 °C (L)	112	153	
Buffer at 70 °C (L)	175	139	

1

(1) Average buffer temp. 65 °C, DHW from 10 to 45° C (2) from 10 to 45 °C (3) Buffer at 70 °C, DHW from 10 to 45° C

NL (3)

## TW1 HP auxiliary heat exchanger performance

CODE	TW1 HP 00300 R	TW1 HP 00400 R	
Heat exchanger m² (L)	1,2 (4,1)	1,3 (4,5)	
Power (kW)			
$\Delta T^{(4)} = 10^{\circ} C$	6,3	6,8	
$\Delta T^{(4)} = 15^{\circ} C$	9,5	10,2	
$\Delta T^{(4)} = 20^{\circ} C$	12,6	13,6	
$\Delta T^{(4)} = 25^{\circ} C$	15,8	17,0	

(4)  $\Delta T$ : difference between the average temperature of the heating fluid (inside the heat exchanger) and the average temperature of the heated fluid (internal to the buffer in the area affected by the coil).